LIMITING VALUES OF MEASURED EARTH FAULT LOOP IMPEDANCES FOR COMMON OVERCURRENT PROTECTIVE DEVICES, FOR INDIRECT CONTACT, OPERATING AT 230 V BASED ON 80% (APPROX.) OF THE VALUE GIVEN IN BS 7671: 1992

Nominal Rating (A)	Fuses						Circuit-breakers to BS 3871 or BS EN 60898				
	BS 88 ' gG' Parts 2 and 6		BS 1361		BS 3036		Type 1	Type 2	Type B	Type 3 and C	Type D
	0.4 s	5 s	0.4 s	5 s	0.4 s	5 s	0.4 s and 5 s				
5	N/A	N/A	8.72	13.68	8.00	14.80	9.60	5.48	N/A	3.84	1.92
6	7.11	11.28	N/A	N/A	N/A	N/A	8.00	4.56	6.40	3.20	1.60
10	4.26	6.19	N/A	N/A	N/A	N/A	4.80	2.74	3.84	1.92	0.96
15	N/A	N/A	2.74	4.17	2.13	4.46	3.20	1.83	N/A	1.28	0.64
16	2.25	3.48	N/A	N/A	N/A	N/A	3.00	1.71	2.40	1.20	0.60
20	1.48	2.43	1.42	2.34	1.48	3.20	2.40	1.36	1.92	0.96	0.48
25	1.20	1.92	N/A	N/A	N/A	N/A	1.92	1.09	1.53	0.76	0.38
30	N/A	N/A	0.96	1.53	0.91	2.20	1.60	0.91	N/A	0.64	0.32
32	0.87	1.53	N/A	N/A	N/A	N/A	1.50	0.85	1.20	0.60	0.30
40	0.68	1.12	N/A	N/A	N/A	N/A	1.20	0.68	0.96	0.48	0.24
45	N/A	N/A	0.48	0.80	0.49	1.32	1.06	0.60	0.85	0.42	0.21
50	0.50	0.87	N/A	N/A	N/A	N/A	0.96	0.55	0.76	0.38	0.19
60	N/A	N/A	N/A	0.58	N/A	0.93	N/A	N/A	N/A	N/A	N/A
63	0.38	0.68	N/A	N/A	N/A	N/A	0.76	0.43	0.60	0.30	0.15
80	N/A	0.48	N/A	0.41	N/A	N/A	0.60	0.34	0.48	0.24	0.12
100	N/A	0.35	N/A	0.30	N/A	0.44	0.48	0.27	0.38	0.19	0.09
125	N/A	0.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
160	N/A	0.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
200	N/A	0.16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A